



Livingston County Drain Commissioners Office

2300 East Grand River Avenue, Suite 105, Howell, MI 48843-7581

Phone: 517-546-0040 / Fax: 517-545-9658

Website: www.livgov.com/drain Email: drain@livgov.com

SUSPENSION OF TREATMENT INSPECTION FORM

Site Inspection for LIVINGSTON REGIONAL SANITARY SEWER

Connections with GRINDER PUMP

FEE: \$225

Date: _____ Owner Name: _____ Phone: _____

Applicant (if other than Owner): _____ Phone: _____

Site Address, City, State, Zip: _____

Parcel ID No: 47 _ _ - _ _ - _ _ - _ _

NOTE: This policy requires your township permission.

Drain Office Use:

Amount Paid: _____ Check # _____ Cash () MasterCard/Visa ()

Received by: _____ Date: _____ City Works Request: _____

Notified: Twp. () LCBD: () Do's and Don'ts () Signed Access Agreement ()

The request to suspend service prevents water removal. Sewer backflow is stopped at the street but the County is not liable for incidental water that may accumulate in the residence. The property owner is responsible for all damages onsite while service is disconnected. If damage requires replacement of any equipment, all parts and labor to restore service are property owner expenses. An escrow sufficient to cover 120% of the estimated costs and inspection fees shall be established at the Office of the Drain Commissioner when restoration of service is requested. Upon completion of repairs and inspection, the remaining escrow shall be remitted to property owner

- THE GRINDER PUMP # _____ HAS BEEN REMOVED
- THE GRINDER PUMP WET WELL (CAN) AND LID HAS BEEN INSPECTED, PHOTOGRAPHED AND FOUND TO BE WITHOUT DAMAGE OR CRACKS
- THE POWER CORD FROM THE CONTROL PANEL AT THE BUILDING TO THE GRINDER PUMP MUST BE REPLACED? YES NO
- CONTROL PANEL IS INTACT AND FUNCTIONING? YES NO
- THE CONTROL PANEL MUST BE REPLACED? YES NO
- THE CONTROL CIRCUIT FOR THE PUMP SHALL BE ON A DEDICATED CIRCUIT *(Must be sufficient for the power requirement of the equipment manufacturer.)*
- CONTROL PANEL MUST BE INSTALLED AT LEAST 5' ABOVE FINISHED GRADE AND IN VIEW OF THE TANK
- THE CURB STOP VALVE AND/OR CHECK VALVE MUST BE REPLACED?
CURB STOP VALVE YES NO CHECK VALVE YES NO

COMMENTS and ADDITIONAL EXPENSE(S): _____

Inspected by: _____ Property Owner _____
Signature Signature